

---

---

## ADDENDA 3 - CORRECTED

---

---

**DATE:** 3/6/2009  
**TO:** BIDDERS  
**CC:** AGC PLAN ROOM ; HABERSHAM COUNTY (LEWIS CANUP)  
**FROM:** JASON SMITH  
**RE:** INDUSTRIAL BOULEVARD WATER AND SEWER EXTENSION

---

1. **Restrained joint C900 only necessary in Jack & Bore – not entire length of pipe**

